

J.R. Garza
Mayor


Oscar Salinas
Mayor Pro-Tem

Pete Morales
Commissioner

Roel Moreno Jr
Commissioner

Arturo Garcia
Commissioner

Robert L. Salinas
City Manager



ADDENDUM NO. 2
November 25, 2024

CITY OF ALAMO
WATER TREATMENT PLANT CLARIFIERS REHABILITATION AND PROTECTIVE COATING
RFB#: 24 -11-12

Notice is hereby given to all perspective respondents of the following:

Bid Schedule has been modified as follows:

Deadline to Submit Final Addendum: **MONDAY, DECEMBER 2, 2024, AT 5:00 PM (IF NECESSARY)**
Bid Date: **THURSDAY, DECEMBER 5, 2024 AT 3:00 PM**

RESPONSES TO QUESTIONS

- 1. Please clarify any noise abatement concerns or requirements. The sandblasting process may be a noisy process.**

Response:
The Contractor will limit sandblasting activities to between 8:00 AM and 7:00 PM.

- 2. Will Contractor be allowed to work at night.**

Response:
Yes, the Contractor will be allowed to work at night but any work that generates too much noise, such as sandblasting is not allowed.

- 3. Will Contractor be required to shroud (cover) the clarifier during coating process.**

Response:
Specifications outline the necessary procedures and protective measures during the coating application. Please note that the coating process is sensitive to the environment in terms of humidity, temperature, dust, and debris. Therefore, the expectation is that the Contractor will shroud or enclose the basin to ensure proper application.

CHANGES TO THE SPECIFICATIONS AND GENERAL REQUIREMENTS

- 1. Standard Requirements, Item 13: Remove and replace in its entirety and replace with the following:**

A **Pre-Bid Conference** is to be held at the City of Alamo Water Treatment Plant, 800 N 9th Pl, Alamo, Texas 78516 on **Wednesday, November 20, 2024, at 10:30 AM** for all prospective bidders to clarify any questions pertaining to the specifications. Attendance is not necessary to be considered for an award.

If Contractor would like to conduct a site visit prior to bidding, please contact Adela Perez at aperez@alamotexas.org

2. Section Statement of Bidder's Experience (SBE): New Section. Contractor shall complete and submit with bid completed SBE Form demonstrating previously experience as noted.

CLARIFICATIONS


1. Revised bid date matches original advertisement in local newspaper.
2. Pre-bid meeting is not mandatory, and attendance is not required to submit a bid.
3. Contract days are 90 days and will commence at Notice to Proceed (NTP) Date. City will assess a \$250 per day liquidated damage fee to the Contractor. Contractor may submit additional days for any unforeseen delays or inclement weather for Owner/Engineer's consideration.

END OF ADDENDUM


This Addendum is 5 pages in its entirety.

Attachments:

Section SBE – Statement of Bidder's Experience (SBE) (3 pages total)



Javier Garcia, P.E.
Garcia Infrastructure Consultants, L.L.C



Complete and email this acknowledgement to aperez@alamotexas.org

Acknowledge receipt of Addendum No. 2:

Authorized Signature

Printed Name

Company Name

**STATEMENT OF BIDDER'S
EXPERIENCE**

**CITY OF ALAMO WTP
WATER TREATMENT PLANT CLARIFIERS REHABILITATION AND
PROTECTIVE COATING**

RFB#: 24 -11-12

A. Please complete all the fields below. Contracts A-1, A-2, and A-3 shall be separate contracts.

Bidder must answer all questions completely and all information must be clear, accurate and comprehensive.

If all fields are not completed, the Bid is at risk for being rejected due to non-responsiveness. It is not acceptable to indicate "See attached".

Contract A-1 is to have been completed by the Bidder.

- Contract A-1 demonstrates experience with coating steel structures of similar size to the Alamo WTP Clarifiers.
- Contract A-1 was completed between 2010 and 2024.

Contract A-1 Description

Name of Contract: _____ Location: _____

Scope of Work: _____

Pipe Sizes: _____ Pipe Lengths: _____

*Owner Point of Contact (POC): _____ Owner POC Title: _____

Owner POC Phone Number: _____ Construction Cost: _____

Contract Start Date: _____ Contract End Date: _____

Additional Information: _____

*Owner is defined as entity the Bidder performed work for (i.e. City, County, Utility, State, etc.)

Bidder must provide a specific name with contact information that has previously verified. The design engineer may not serve as reference for the Bidder.

If all fields are not completed, the Bid is at risk for being rejected due to non-responsiveness. It is not acceptable to indicate “See attached”.

Contract A-2 is to have been completed by the Bidder.

- Contract A-2 demonstrates experience with coating concrete or steel structures at a water or wastewater treatment facility.
- Contract A-2 was completed between 2010 and 2024.
- Contract A-2 can be the same as Project A-1

Contract A-2 Description

Name of Contract: _____ Location: _____

Scope of Work: _____

Pipe Sizes: _____ Pipe Lengths: _____

*Owner Point of Contact (POC): _____ Owner POC Title: _____

Owner POC Phone Number: _____ Construction Cost: _____

Contract Start Date: _____ Contract End Date: _____

Additional Information: _____

*Owner is defined as entity the Bidder performed work for (i.e. City, County, Utility, State, etc.)

Bidder must provide a specific name with contact information that has previously verified. The design engineer may not serve as reference for the Bidder.

If all fields are not completed, the Bid is at risk for being rejected due to non-responsiveness. It is not acceptable to indicate “See attached”.

Contract A-3 is to have been completed by the Bidder or Sub-Contractor.

- Contract A-3 demonstrates experience with coating concrete or steel structures at a water or wastewater treatment facility.
- Contract A-3 was completed between 2010 and 2024.
- Contract A-3 cannot be the same as Project A-1 or A-2

Contract A-3 Description

Name of Project: _____ Location: _____

Scope of Work: _____

Pipe Sizes: _____ Pipe Lengths: _____

*Owner Point of Contact (POC): _____ Owner POC Title: _____

Owner POC Phone Number: _____ Construction Cost: _____

Contract Start Date: _____ Contract End Date: _____

Additional Information: _____

*Owner is defined as entity the Bidder performed work for (i.e. City, County, Utility, State, etc.)

Bidder must provide a specific name with contact information that has previously verified. The design engineer may not serve as reference for the Bidder.